

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	http://www.tumut.nsw.gov.au/wp-content/uploads/Talbingo-WTP-Map.pdf								
Licence Link	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79291&SYSUID=1&LICID=11195								
Licence Number: 11195						BOD	pH	Susp.Solids	Tot Oil & Grease
Talbingo WTP Lagoon Effluent						BOD Result	pH	Susp_solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile						20	6.5 - 8.5	30	10
Talbingo Water Plant Effl	TALWTP-PT1	CA1803592-002	21/06/2018	28/06/2018	12/06/2018	<2	7.64	7	<1
Talbingo Water Plant Eff	TALWTP-PT1	CA1805584-002	24/09/2018	14/11/2018	13/09/2018	<2	7.44	5	<1
Talbingo Water Plant Effl	TALWTP-PT1	CA1807422-002	13/12/2018	21/12/2018	5/12/2018	2	7.69	<2	<1
Talbingo Water Plant Effl	TALWTP-PT1								
Talbingo Water Plant Effl	TALWTP-PT1								

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-WTP-Map.pdf								
Licence Link	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79289&SYSUID=1&LICID=2503								
Licence Number: 2503						BOD	pH	Susp.Solids	Tot Oil & Grease
Tumut WTP Lagoon Effluent						BOD Result	pH	Susp_solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile							6.5 - 8.5	30	
Tumut Water Plant Effluen	TUMWTP-EPAPt1	CA1803529-001	15/06/2018	28/06/2018	8/06/2018	<2	7.47	2	<1
Tumut Water Plant Effluen	TUMWTP-EPAPt1	CA1805415-001	14/09/2018	14/11/2018	5/09/2018	<2	7.47	2	<1
Tumut Water Plant Effluen	TUMWTP-EPAPt1	CA1807422-001	13/12/2018	21/12/2018	5/12/2018	<2	7.51	<2	<1
Tumut Water Plant Effluen	TUMWTP-EPAPt1								

Anniversary Date: 15 September