

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	http://www.tumut.nsw.gov.au/wp-content/uploads/Talbingo-WTP-Map.pdf								
Licence Link	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79291&SYSUID=1&LICID=11195								
Licence Number: 11195						BOD	pH	Susp.Solids	Tot Oil & Grease
Talbingo WTP Lagoon Effluent						BOD Result	pH	Susp_solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile						20	6.5 - 8.5	30	10
Talbingo Water Plant Effl	TALWTP-PT1	CA1803592-002	21/06/2018	28/06/2018	12/06/2018	<2	7.64	7	<1
Talbingo Water Plant Eff	TALWTP-PT1	CA1805584-002	24/09/2018	14/11/2018	13/09/2018	<2	7.44	5	<1
Talbingo Water Plant Effl	TALWTP-PT1	CA1807422-002	13/12/2018	21/12/2018	5/12/2018	2	7.69	<2	<1
Talbingo Water Plant Effl	TALWTP-PT1								
Talbingo Water Plant Effl	TALWTP-PT1								

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-WTP-Map.pdf								
Licence Link	http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79289&SYSUID=1&LICID=2503								
Licence Number: 2503						BOD	pH	Susp.Solids	Tot Oil & Grease
Tumut WTP Lagoon Effluent						BOD Result	pH	Susp_solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile							6.5 - 8.5	30	
Tumut Water Plant Effluen	TUMWTP-EPAP1	CA1803529-001	15/06/2018	28/06/2018	8/06/2018	<2	7.47	2	<1
Tumut Water Plant Effluen	TUMWTP-EPAP1	CA1805415-001	14/09/2018	14/11/2018	5/09/2018	<2	7.47	2	<1
Tumut Water Plant Effluen	TUMWTP-EPAP1	CA1807422-001	13/12/2018	21/12/2018	5/12/2018	<2	7.51	<2	<1
Tumut Water Plant Effluen	TUMWTP-EPAP1								

Anniversary Date: 15 September

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results							
Site Map													
Licence Link	http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=106689&SYSUID=1&LICID=448												
Licence Number: 448						Ammonia (asN)	Total Nitrogen	Tot.Phosp (asP)	BOD	pH	Susp.Solids	Tot Oil & Grease	Faecal Coliform Env.
Tumbarumba STP Effluent Samples						Ammonia	Total_N	Total_P	BOD Result	pH	Susp_solids	Oil & grease	Conf_Count
						mg/L N	mg/L N	mg/L P	mg/L	pH units	mg/L	mg/L	CFU/100mL
Licence Limit -100 percentile						5	20	0.6	20	6.5 - 8.5	30	5	1000
Tumbarumba STP Effluent	EPA-P1	1709-0048	26/09/017	27/09/2017	12/09/017	0.4	5	0.06	<2	8	7	3	<1
Tumbarumba STP Effluent	EPA-P1	1712-0072	22/12/2017	21/02/2018	13/12/2017	<0.1	6	0.58	10	7.8	71	1	90
Tumbarumba STP Effluent	EPA-P1	1803-0059	29/03/2018	20/04/2018	13/03/2018	0.2	53	0.37	5	8.3	28	<1	230
Tumbarumba STP Effluent	EPA-P1	1804-0131	24/04/2018	25/05/2018	9/04/2018	<0.1	8	<0.01	<2	8.6	8	<1	7
Tumbarumba STP Effluent	EPA-P1	1807-0448	2/08/2018	14/11/2018	24/07/2018	0.4	11	0.15	<2	7.9	<2	<1	<1
Tumbarumba STP Effluent	EPA-P1	1810-0281	31/10/2018	14/11/2018	16/10/2018	0.4	5	0.12	<2	8	2	2	10

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results				
Site Map										
Licence Link	http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79211&SYSUID=1&LICID=4400									
Licence Number: 4400						Total Nitrogen	Tot.Phosp (asP)	BOD	Sodium Adsorption	Conductivity
Khancoban STP Effluent Samples						Total_N	Total_P	BOD Result		
						mg/L N	mg/L P	mg/L	uS/cm	uS/cm
Licence Limit -100 percentile						NA	NA	NA	NA	NA
Khancoban STP Effluent	EPA-P2	1709-0048	26/09/017	27/09/2017	12/09/017	23	4.15	16	1	
Khancoban STP Effluent	EPA-P2	1804-0130	24/04/2018	25/05/2018	9/04/2018	50	8.47	22	2	

EPL 4400 surrendered May 2017