



Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results									
<b>Site Map</b>						<a href="http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-STP-Map.pdf">http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-STP-Map.pdf</a>									
<b>Licence Link</b>						<a href="http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79242&amp;SYSUID=1&amp;LICID=210">http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79242&amp;SYSUID=1&amp;LICID=210</a>									
<b>Licence Number: 210</b>						<b>Ammonia (asN)</b>	<b>Total Nitrogen</b>	<b>Tot.Phosp (asP)</b>	<b>BOD</b>	<b>pH</b>	<b>Susp.Solids</b>	<b>Tot Oil &amp; Grease</b>	<b>Faecal Coliform Env.</b>		<b>Conductivity</b>
<b>Tumut STP Effluent Samples</b>						<b>Ammonia</b>	<b>Total N</b>	<b>Total P</b>	<b>BOD Result</b>	<b>pH</b>	<b>Susp_solids</b>	<b>Oil &amp; grease</b>	<b>Pres_Count</b>	<b>Conf_Count</b>	
						<b>mg/L N</b>	<b>mg/L N</b>	<b>mg/L P</b>	<b>mg/L</b>	<b>pH units</b>	<b>mg/L</b>	<b>mg/L</b>	<b>CFU/100mL</b>	<b>CFU/100mL</b>	<b>uS/cm</b>
<b>Licence Limit -100 percentile</b>						<b>5</b>	<b>20</b>	<b>0.6</b>	<b>20</b>	<b>6.5 - 8.5</b>	<b>30</b>	<b>10</b>	<b>1000</b>	<b>1000</b>	<b>-</b>
Tumut STP Effluent	TUM EPA-P1	CA2103687-001	22/06/2021	24/06/2021	9/06/2021	0.8	3.45	0.07	<2	7.58	5	<1	<1	<1	363
Tumut STP Effluent	TUM EPA-P1	CA2104303-001	19/07/2021	21/07/2021	7/07/2021	0.5	2.88	0.06	<2	7.66	7	<1	2	<2	366
Tumut STP Effluent	TUM EPA-P1	CA2104943-001	17/08/2021	3/09/2021	5/08/2021	0.6	3.13	0.07	<2	7.59	4	<1	<1	<1	326
Tumut STP Effluent	TUM EPA-P1	CA2105591-001	17/09/2021	28/09/2021	9/09/2021	0.5	3.64	0.07	<2	7.65	3	<1	6	6	354
Tumut STP Effluent	TUM EPA-P1	CA2106189-001	19/10/2021	4/11/2021	7/10/2021	0.4	3.26	0.06	<2	7.13	2	<1	15	15	352
Tumut STP Effluent	TUM EPA-P1	CA2106875-001	17/11/2021	29/11/2021	5/11/2021	0.3	4.26	0.06	2	6.99	2	<1	<1	<1	379
Tumut STP Effluent	TUM EPA-P1	CA2107808-001	20/12/2021	27/01/2022	8/12/2021	0.5	3.25	0.05	3	6.89	4	<1	4	2	364
Tumut STP Effluent	TUM EPA-P1	CA2200591-001	7/02/2022	2/03/2022	20/01/2022	<0.1	4.82	0.06	<2	6.58	8	<1	8	8	363
Tumut STP Effluent	TUM EPA-P1	CA2200959-001	22/02/2022	2/03/2022	10/02/2022	0.6	4.03	0.09	<2	7.87	12	<1	12	12	491
Tumut STP Effluent	TUM EPA-P1	CA2201734-001	22/03/2022	1/04/2022	9/03/2022	0.8	7.98	0.04	<2	7.93	4	<1	4	4	434
Tumut STP Effluent	TUM EPA-P1	CA2202431-001	20/04/2022	4/05/2022	6/04/2022	1	4.76	0.06	2	7.76	3	<1	<1	<1	392
Tumut STP Effluent	TUM EPA-P1	CA2203340-001	23/05/2022	6/06/2022	11/05/2022	1	3.67	0.04	<2	7.91	5	<1	<2	<2	368

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
<b>Site Map</b>						<a href="http://www.tumut.nsw.gov.au/wp-content/uploads/Talbingo-WTP-Map.pdf">http://www.tumut.nsw.gov.au/wp-content/uploads/Talbingo-WTP-Map.pdf</a>			
<b>Licence Link</b>						<a href="http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79291&amp;SYSUID=1&amp;LICID=11195">http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79291&amp;SYSUID=1&amp;LICID=11195</a>			
<b>Licence Number: 11195</b>						<b>BOD</b>	<b>pH</b>	<b>Susp.Solids</b>	<b>Tot Oil &amp; Grease</b>
<b>Talbingo WTP Lagoon Effluent</b>						<b>BOD Result</b>	<b>pH</b>	<b>Susp_solids</b>	<b>Oil &amp; grease</b>
						<b>mg/L</b>	<b>pH units</b>	<b>mg/L</b>	<b>mg/L</b>
<b>Licence Limit -100 percentile</b>						<b>20</b>	<b>6.5 - 8.5</b>	<b>30</b>	<b>10</b>
Talbingo Water Plant Effl	TALWTP-PT1	CA2103689-002	22/06/2021	24/06/2021	9/06/2021	<2	8.58	9	<1
Talbingo Water Plant Effl	TALWTP-PT1	CA2105737-002	28/09/2021	14/10/2021	15/09/2021	2	7.97	9	<1
Talbingo Water Plant Effl	TALWTP-PT1	CA2107837-002	21/12/2021	27/01/2022	8/12/2021	<2	7.02	16	<1
Talbingo Water Plant Effl	TALWTP-PT1	CA2201735-002	22/03/2022	1/04/2022	9/03/2022	<2	7.63	13	<1

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
<b>Site Map</b>						<a href="http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-WTP-Map.pdf">http://www.tumut.nsw.gov.au/wp-content/uploads/Tumut-WTP-Map.pdf</a>			
<b>Licence Link</b>						<a href="http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79288&amp;SYSUID=1&amp;LICID=2503">http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79288&amp;SYSUID=1&amp;LICID=2503</a>			
<b>Licence Number: 2503</b>						<b>BOD</b>	<b>pH</b>	<b>Susp.Solids</b>	<b>Tot Oil &amp; Grease</b>
<b>Tumut WTP Lagoon Effluent</b>						<b>BOD Result</b>	<b>pH</b>	<b>Susp_solids</b>	<b>Oil &amp; grease</b>
						<b>mg/L</b>	<b>pH units</b>	<b>mg/L</b>	<b>mg/L</b>
<b>Licence Limit -100 percentile</b>						<b>6.5 - 8.5</b>	<b>30</b>		
Tumut Water Plant Effluent	TUMWTP-EPAP1	CA2103689-001	22/06/2021	24/06/2021	9/06/2021	<2	7.74	4	<1
Tumut Water Plant Effluent	TUMWTP-EPAP1	CA2105737-001	28/09/2021	14/10/2021	15/09/2021	<2	7.87	4	<1
Tumut Water Plant Effluent	TUMWTP-EPAP1	CA2107837-001	21/12/2021	27/01/2022	8/12/2021	<2	7.13	5	<1
Tumut Water Plant Effluent	TUMWTP-EPAP1	CA2201735-001	22/03/2022	1/04/2022	9/03/2022	<2	7.82	6	<1

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results							
Site Map													
Licence Link	<a href="http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=1186894&amp;SYSUID=1&amp;LICID=448">http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=1186894&amp;SYSUID=1&amp;LICID=448</a>												
Licence Number: 448						Ammonia (asN)	Total Nitrogen	Tot.Phosp (asP)	BOD	pH	Susp.Solids	Tot Oil & Grease	Faecal Coliform Env.
Tumbarumba STP Effluent Samples						Ammonia	Total_N	Total_P	BOD_Result	pH	Susp_solids	Oil & grease	Conf_Count
Monitoring Frequency - Quarterly						mg/L N	mg/L N	mg/L P	mg/L	pH units	mg/L	mg/L	CFU/100mL
<b>Licence Limit -100 percentile</b>						<b>5</b>	<b>20</b>	<b>0.6</b>	<b>20</b>	<b>6.5 - 8.5</b>	<b>30</b>	<b>5</b>	<b>1000</b>
Tumbarumba STP Effluent	EPA-P1	CA2103494-001	10/06/2021	24/06/2021	1/06/2021	0.3	11.3	0.12	10	8.13	5	<1	2
Tumbarumba STP Effluent	EPA-P1	CA2106277-001	21/10/2021	4/11/2021	12/10/2021	<0.1	4.84	0.06	4	7.6	9	<1	<2
Tumbarumba STP Effluent	EPA-P1	CA2107947-001	23/12/2021	27/01/2021	14/12/2021	0.7	5.87	0.1	4	7.87	16	<1	34
Tumbarumba STP Effluent	EPA-P1	CA2201486-001	13/03/2022	1/04/2022	1/03/2022	1.3	11	0.25	6	7.86	10	<1	28

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results					
Site Map											
Licence Link	<a href="http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79211&amp;SYSUID=1&amp;LICID=4400">http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=79211&amp;SYSUID=1&amp;LICID=4400</a>										
Licence Number: 4400						Total Nitrogen	Tot.Phosp (asP)	BOD	Sodium Adsorption	Conductivity	
Khancoban STP Effluent Samples						Total_N	Total_P	BOD_Result			
Monitoring frequency - bi-annual						mg/L N	mg/L P	mg/L	uS/cm	uS/cm	
<b>Licence Limit -100 percentile</b>						<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	<b>NA</b>	
Khancoban STP Effluent	EPA-P1	CA2105557-001	14/09/2021	28/09/2021	7/09/2021	9.44	0.89	4	0.61	128	
Khancoban STP Effluent	EPA-P1	CA2201485-001	8/03/2022	1/04/2022	1/03/2022	29.7	4.42	19	1.84	360	

EPL 4400 surrendered May 2017