

Snowy Valleys Council

Performance Monitoring 2025-2026

In accordance with the Protection of the Environment Operations Act 1997 (POEO Act)
Snowy Valleys Council, 76 Capper Street, TUMUT NSW 2720

(Former Tumut Shire) Anniversary Date: 1 June

[illegible][illegible][illegible][illegible]

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results									
Site Map	https://www.snowyvalleys.nsw.gov.au/files/assets/public/waste-water-files/epl-maps/tumut-stp.pdf														
Licence Link	https://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=1956994&SYSUID=1&LICID=210														
Licence Number: 210						Ammonia (asN)	Total Nitrogen	Tot.Phosp (asP)	BOD	pH	Susp.Solids	Tot Oil & Grease	Faecal Coliform Env.		Conductivity
Tumut STP Effluent Samples						Ammonia mg/L N	Total N mg/L N	Total P mg/L P	BOD Result mg/L	pH pH units	Susp. solids mg/L	Oil & grease mg/L	Pres. Count CFU/100mL	Conf. Count CFU/100mL	uS/cm
Licence Limit -100 percentile						5	20	0.6	20	6.5 - 8.5	30	10	1000	1000	-
Tumut STP Effluent	TUMEPa-P1	CA2503523-001	2025-06-23	2025-06-23	2025-06-11	<0.1	0.46	0.11	<2	7.29	2	<1	3	3	51
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														
Tumut STP Effluent	TUMEPa-P1														

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	https://www.snowyvalleys.nsw.gov.au/files/assets/public/waste-water-files/epl-maps/talbingo-wtp.pdf								
Licence Link	https://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=79291&SYSUID=1&LICID=11195								
Licence Number: 11195						BOD	pH	Susp.Solids	Tot Oil & Grease
Talbingo WTP Lagoon Effluent						BOD Result	pH	Susp. solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile						20	6.5 - 8.5	30	10
Talbingo Water Plant Effl	TALWTP-PT1	CA2503522-002	2025-06-23	2025-06-23	2025-06-11	<2	6.99	6	<1
Talbingo Water Plant Effl	TALWTP-PT1								
Talbingo Water Plant Effl	TALWTP-PT1								
Talbingo Water Plant Effl	TALWTP-PT1								

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results			
Site Map	https://www.snowyvalleys.nsw.gov.au/files/assets/public/waste-water-files/epl-maps/tumut-wtp.pdf								
Licence Link	https://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=79291&SYSUID=1&LICID=2503								
Licence Number: 2503									
Tumut WTP Lagoon Effluent						BOD	pH	Susp.Solids	Tot Oil & Grease
						BOD Result	pH	Susp. solids	Oil & grease
						mg/L	pH units	mg/L	mg/L
Licence Limit -100 percentile							6.5 - 8.5	30	10
Tumut Water Plant Effluent	TUMWTP-EPAP1	CA2503522-001	2025-06-23	2025-06-23	2025-06-11	<2	7.10	<2	<1
Tumut Water Plant Effluent	TUMWTP-EPAP1								
Tumut Water Plant Effluent	TUMWTP-EPAP1								
Tumut Water Plant Effluent	TUMWTP-EPAP1								

(Former Tumbarumba Shire) Anniversary Date: 15 September

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results								
Site Map	https://www.snowyvalleys.nsw.gov.au/files/assets/public/waste-water-files/epl-maps/tumbarumba-wtp.pdf													
Licence Link	https://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=79291&SYSUID=1&LICID=448													
Licence Number: 448						Ammonia (asN)	Total Nitrogen	Tot.Phosp (asP)	BOD	pH	Susp.Solids	Tot Oil & Grease	Faecal Coliform Env.	
Tumbarumba STP Effluent Samples						Ammonia mg/L N	Total N mg/L N	Total P mg/L P	BOD Result mg/L	pH pH units	Susp. solids mg/L	Oil & grease mg/L	Conf. Count CFU/100mL	
Monitoring Frequency - Quarterly						5	20	0.6	20	6.5 - 8.5	30	5	1000	
Licence Limit -100 percentile						5	20	0.6	20	6.5 - 8.5	30	5	1000	
Tumbarumba STP Effluent	EPA-P1	CA2503342-001	2025-06-13	2025-06-23	2025-06-03	0.3	17.8	0.16	<2	7.97	3	<1	20	
Tumbarumba STP Effluent	EPA-P1													
Tumbarumba STP Effluent	EPA-P1													
Tumbarumba STP Effluent	EPA-P1													

Location	Sample Pt	Sample Number	Test Data Received	Publishing Date	Sample Date	Analysis Results				
Site Map	https://www.snowyvalleys.nsw.gov.au/files/assets/public/waste-water-files/epl-maps/khancoban-stp.pdf									
Licence Link	https://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=79211&SYSUID=1&LICID=4400									
Licence Number: 4400						Total Nitrogen	Tot.Phosp (asP)	BOD	Sodium Adsorption	Conductivity
Khancoban STP Effluent Samples						Total N	Total P	BOD Result	uS/cm	uS/cm
Monitoring frequency - bi-annual						mg/L N	mg/L P	mg/L	uS/cm	uS/cm
Licence Limit -100 percentile						NA	NA	NA	NA	NA
Khancoban STP Effluent	EPA-P1	CA2503336-001	2025-06-12	2025-06-23	2025-06-03	61.3	9.31	22	2.81	778
Khancoban STP Effluent	EPA-P1									
Khancoban STP Effluent	EPA-P1									
Khancoban STP Effluent	EPA-P1									

EPL 4400 surrendered May 2017